

Attestation

CDPH CA01350

On 30 May 2017, Eurofins Product Testing A/S received a sample of a compact laminated panel with the product name:

PRINT HPL STR.
supplied by
Abet Laminati S.p.A

The emissions were tested according to CDPH Section 01350. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 in the latest versions, see the test report no. 392-2017-00192301_H_EN_Rev1.

Evaluation of the emission test result according to CDPH Section 01350 / CA01350


- No carcinogens and reproductive/developmental toxins could be detected.
- No individual compound exceeds one-half of the lowest concentrations of interest in a building (chronic REL).
- The requirements were passed both in reference to classrooms and office buildings.

The tested product complies with the requirements of the “Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.2)” as defined by the California Department of Public Health (CDPH) – Version of January 2017.

25 July 2017



Maria Pelle Madsen
Analytical Chemist



Thomas Bjerring
Analytical Service Manager